

# Cooling Towers

- Avoid point isolation
- Best isolation is restrained spring isolators with continuous dunnage beams
- Select isolator deflection based on the ASHRAE Handbook guidelines
- Use molded neoprene pipe flexes
- Specify silencer banks for air inlet attenuation
- Specify acoustical barrier walls for controlling radiated noise in the community

