

Outdoor Chillers

- Thickened roof slab
- Evaluate loudness and tonal content
- Special consideration for remote evap piping
- Special considerations for isolation on screw chillers
- Molded neoprene pipe flexes
- Optimize aerodynamic and acoustic performance
- Avoid roof midspan locations
- Utilize Source and/or path acoustical treatments

